

# KOHLER<sup>®</sup> POWER SYSTEMS

# PARTS BULLETIN

ISSUE DATE: 11/92 MODEL: 4, 5, 7kW  
REVISION DATE: - RV/Mobile

SUBJECT: **Circuit Breaker** NO.: 40  
**Replacement**

Circuit breakers for the 4, 5, and 7kW RV/Mobile Confidant generator sets (Specs. 101203 - 140265) have been changed to meet NEC code. The new circuit breakers have changed to a single handle on the two and three pole versions. Order the new breaker number when replacing the old breaker listed below.

Cover Assembly Number	Breaker Rating	Old Breaker Number	New Breaker Number
A-278695	17 Amp. - 2 Pole	278699 (2)	227671
A-278786	20 Amp. - 2 Pole	278257 (2)	227670
A-278966	25 Amp. - 2 Pole	278784 (2)	227672
A-227449	10 Amp. - 3 Pole	228646 (3)	227673
A-227450	15 Amp. - 3 Pole	278700 (3)	227674
A-227526	20 Amp. - 2 Pole	278257 (2)	227670
A-278892	25 Amp. - 2 Pole	278784 (2)	227672
A-278893	17 Amp. - 3 Pole	278699 (3)	227675
A-278962	30 Amp. - 2 Pole	278190 (2)	227669

NOTE: ( ) indicates the quantity of the old breaker used per assembly. All new breakers have a quantity of one per assembly.

Routing	Service Manager	Sales Manager	Parts Manager	Technician No. 1	Technician No. 2	Technician No. 3	Return This to
Initial Here							

