

# KOHLER® POWER SYSTEMS

## SERVICE BULLETIN

ISSUE DATE: **2/90**      MODEL: **3.5 -- 7CM**  
 REVISION DATE: --

SUBJECT: **Controller Replacement**      NO.: **495**

The solid state "Decision Maker" controller and interlock circuit board on 3.5 through 7CM- -RV generators is being replaced by the relay controller and interlock relays provided in the kits listed below. If you are replacing the solid state controller (C- -269155), controller main circuit board (C- -269148), controller switch circuit board (C- -269149), or interlock circuit board (C- -269150) on these models, it

is necessary to install a new controller and new interlock relay. The new controller assembly is an exact replacement of the original. The interlock relay assembly includes a wiring harness that will mate with the original harness. These kits offer improved reliability and can be ordered through generator service parts.

Model No.	3.5 CM	4.5 CM	5.5/7 CM
<b>Kit Number (includes *)</b>	<b>228552</b>	<b>228554</b>	<b>228553</b>
* Controller Assembly	A- -241994	A- -241994	A- -241994
* Interlock Relay Assembly (4CR)	A- -238755	A- -277821	A- -241760

Routing	Service Manager	Sales Manager	Parts Manager	Technician No. 1	Technician No. 2	Technician No. 3	Return This to
Initial Here							

