


INSTRUCTION MANUAL

MODEL: K711
500KW, 480V, 3P, 60HZ
PARTS #: 76840



Specialists in the Following Services for Industry

DIGITAL MEASUREMENT AND CONTROL SYSTEMS
TEST EQUIPMENT FOR AIRCRAFT ELECTRICAL AND HYDRAULIC COMPONENTS
RESISTIVE AND REACTIVE LOAD BANKS
ROTARY PULSE GENERATORS



All Sales and Service for
Aircraft Test Equipment
7900 E. Pleasant Valley Rd.
Independence, Ohio 44131-5529
TELEPHONE (216) 642-1230
FACSIMILE (216) 642-6037

Service for All
Other Products
10409 Meech Ave
Cleveland, Ohio 44105-4183
TELEPHONE (216) 641-8310
FACSIMILE (216) 341-8803

**AVTRON MODEL K711
LOAD BANK, RESISTIVE, DUCT MOUNT
Serial Number 825 and Above**

Project 251073

**AVTRON MODEL K711
LOAD BANK, RESISTIVE, DUCT MOUNT
Serial Number 825 and Above**

© 1996 Avtron Manufacturing, Inc.
Cleveland, Ohio

October 5, 1996
Rev. July 25, 2000
Rev. March 13, 2002

PROPRIETARY NOTE

This document contains information PROPRIETARY to Avtron Manufacturing, Inc., is furnished solely to provide information sufficient for instruction, operation, maintenance, evaluation, and testing of the equipment herein disclosed, is not to be used for manufacturing or procurement and is not to be disclosed to anyone other than persons in the Division, or the Company, or the Government, as the case may be, responsible for action relating to this document without the express written permission of Avtron Manufacturing, Inc.

WARRANTY

The last page of this document contains an express limited warranty. The provisions of this warranty cover any and all rights extended to holders of Avtron equipment.

WHEN ORDERING SERVICE OR
REPAIR PARTS, PLEASE SPECIFY
MODEL NO. AND/OR PART NO.
LOCATED ON NAMEPLATE AND
DWG. NO. A28592.

DRAWINGS

PROPRIETARY NOTE

The wiring diagrams and schematics which follow contain information PROPRIETARY to Avtron Manufacturing, Inc., are furnished solely to provide information sufficient for instruction, operation, maintenance, evaluation, and testing of the equipment herein disclosed, are not to be used for manufacturing or procurement and are not to be disclosed to anyone other than persons in the Division, or the Company, or the Government, as the case may be, responsible for action relating to this document without the express written permission of Avtron Manufacturing, Inc.

APPLICATION			REVISION:			
MODEL/PART NO. MODIFIED	ECN	LTR	DESCRIPTION	DATE	APPROVAL	
K711-60-60-480F-5G-A,B,K	CD137	A	REV ALL SHT'S PER ECN FACKELMANN	7/31/02	K.KUK	

PARTS NOT REQUIRED

PART NO.	QTY	ASSEMBLY	DESCRIPTION	DISP	REF DESIG
364103	2 REF	TOP/C21392	TERMINAL BOARD	2	TB1
450028	2 REF	TOP/C21392	MARKER STRIP	2	XTB1
364973	1 REF	TOP	DISTRIBUTION BLOCK	2	

NEW PARTS REQUIRED

PART NO.	QTY	ASSEMBLY	DESCRIPTION	DISP	REF DESIG
A24032	1	TOP	NAMEPLATE		
366948	1 REF	TOP	LUG		
364409	2 REF	TOP	END SECTION		
450304	4 REF	TOP	MARKER (1-10)		XTB1
364432	40 REF	TOP	TERMINAL BLOCK		TB1
364433	4 REF	TOP	END BLOCK		
A17451-3	2 REF	TOP	RAIL MOUNTING		
458519	AR	TOP	LABELS		
A21400	1 REF	TOP	LABEL (UL)		

- DISPOSITION
- 1) RETURN TO VENDOR
 - 2) RETURN TO STOCK
 - 3) SCRAP
 - 4) RETURN TO SURPLUS

NEW DRAWINGS _____

PROJECT 251073

WIRING DIAGRAMS AFFECTED _____ SCHEMATICS AFFECTED _____

THIS DOCUMENT CONTAINS PROPRIETARY INFORMATION OF AVTRON MFG., INC. AND MAY NOT BE DISCLOSED TO OTHERS OR USED FOR MANUFACTURING PURPOSES WITHOUT THE WRITTEN CONSENT OF AVTRON MFG.

DRAWN	KUK	DATE	7/22/02
ENG MGR	D.KOZAR	DATE	7/23/02
APP'D PROD	ZIMMERMAN	DATE	7/24/02



TITLE			MODIFICATION, UL OUTDOOR, 500 KW, 480 VAC		
CAGE NO.	SIZE	DRAWING NO.	SH	OF	REV
01014	A	A28592	1	9	A

APPLICATION		REVISION				
MODEL/PART NO. MODIFIED	ECN	LTR	DESCRIPTION	DATE	APPROVAL	
K711-60-60-480F-5G-A,B,K	CD137	A	REV PER ECN	FACKELMANN	7/31/02	K.KUK

PARTS NOT REQUIRED

PART NO.	QTY	ASSEMBLY	DESCRIPTION	DISP	REF DESIG

NEW PARTS REQUIRED

PART NO.	QTY	ASSEMBLY	DESCRIPTION	DISP	REF DESIG
471876	7 REF	TOP	SWITCH BOOTS		
416540	1 REF	TOP	PLUG, 1" DIA.		
416507	6 REF	TOP	PLUG, 3/8" DIA.		
416533	6 REF	TOP	PLUG, 5/8" DIA.		
532739	AR REF	TOP	WASHER, SEAL		
450305	4 REF	TOP	MARKER STRIP (11-20)		
C22156-2	1 REF	TOP	HOOD		
A23206	2 REF	TOP	DESIGNATION PLATE		
B15905	3 REF	TOP	LABEL, WARNING		

- DISPOSITION
- 1) RETURN TO VENDOR
 - 2) RETURN TO STOCK
 - 3) SCRAP
 - 4) RETURN TO SURPLUS

NEW DRAWINGS _____

PROJECT 251073 _____

WIRING DIAGRAMS AFFECTED _____ SCHEMATICS AFFECTED _____

THIS DOCUMENT CONTAINS PROPRIETARY INFORMATION OF AVTRON MFG., INC. AND MAY NOT BE DISCLOSED TO OTHERS OR USED FOR MANUFACTURING PURPOSES WITHOUT THE WRITTEN CONSENT OF AVTRON MFG.

DRAWN	KUK	DATE	7/22/02
ENG MGR	D.KOZAR	DATE	7/23/02
APP'D PROD	ZIMMERMAN	DATE	7/24/02



TITLE		MODIFICATION, UL OUTDOOR, 500 KW, 480 VAC			PSF
CAGE NO.	SIZE	DRAWING NO.	SH	OF	REV
01014	A	A28592	2	9	A

APPLICATION		REVISION				
MODEL/PART NO. MODIFIED	ECN	LTR	DESCRIPTION	DATE	APPROVAL	
K711-60-60-480F-5G-A,B,K	CD137	A	REV PER ECN	7/31/02	FACKELMANN K.KUK	

PARTS NOT REQUIRED

PART NO.	QTY	ASSEMBLY	DESCRIPTION	DISP	REF DESIG

NEW PARTS REQUIRED

PART NO.	QTY	ASSEMBLY	DESCRIPTION	DISP	REF DESIG
471800	AR REF	TOP	GASKET, .25" THICK		
910006	AR REF	TOP	SEALANT, SILICONE		
C24273	3 REF	TOP	BUS BAR		
411505	6 REF	TOP	INSULATOR		

DISPOSITION

- 1) RETURN TO VENDOR
- 2) RETURN TO STOCK
- 3) SCRAP
- 4) RETURN TO SURPLUS

NEW DRAWINGS

PROJECT 251073

WIRING DIAGRAMS AFFECTED _____

SCHEMATICS AFFECTED _____

THIS DOCUMENT CONTAINS PROPRIETARY INFORMATION OF AVTRON MFG., INC. AND MAY NOT BE DISCLOSED TO OTHERS OR USED FOR MANUFACTURING PURPOSES WITHOUT THE WRITTEN CONSENT OF AVTRON MFG.

DRAWN	KUK	DATE	7/22/02
ENC MGR	D.KOZAR	DATE	7/23/02
APP'D PROD	ZIMMERMAN	DATE	7/24/02



TITLE			MODIFICATION, UL OUTDOOR, 500 KW, 480 VAC			PSF
CAGE NO.	SIZE	DRAWING NO.	SH	OF	REV	
01014	A	A28592	3	9	A	

APPLICATION		REVISION				
MODEL/PART NO. MODIFIED	ECN	LTR	DESCRIPTION	DATE	APPROVAL	
K711-60-60-480F-5G-A,B,K	CD137	A	REV PER ECN	FACKELMANN	7/31/02	K.KUK

MODIFICATION REQUIRED

SCOPE

COMPLETE NECESSARY MODIFICATION TO ACHIEVE UL FILE E140848 REQUIREMENTS FOR OUTDOOR K711 LOAD BANK.

INSTALLATION INSTRUCTIONS

1. GENERATE COMPUTER PRINTED LABELS (MATERIAL P/N 458519) AND ATTACH ADJACENT TO EACH FUSEHOLDER THAT READS AS FOLLOWS:

A.) FOR 208V AND 240V LOAD BANKS:

"CLASS T, xxA, 300V FUSE"

(xxA = AMP RATING OF FUSE)

B.) FOR 480V AND 600V LOAD BANKS:

"CLASS T, xxA, 600V FUSE"

(xxA = AMP RATING OF FUSE)

C.) FOR CONTROL PANEL FUSE AND EACH TRANSFORMER FUSE:

"CLASS CC, xxA, 600V FUSE"

(xxA = AMP RATING OF FUSE)

2. GENERATE COMPUTER PRINTED LABELS (MATERIAL P/N 458519) AND ATTACH ONTO LOWER BACK OF CONTROL PANEL NEAR POWER DISTRIBUTION BLOCK AS FOLLOWS:

A.) IF LOAD CONTACTOR QUANTITY IS \leq 5:

"INPUT BUS TORQUE REQUIREMENTS FOR AVTRON P/N 364948

LINE = 500 MCM THRU # 4 AWG = 375 IN. LBS.

LOAD = # 4 AWG THRU #14 AWG = 35 IN. LBS.

USE COPPER, MINIMUM 75 DEGREE C WIRE"

PLEASE NOTE: \leq = LESS THAN OR EQUAL TO THE FOLLOWING NUMBER.
 \geq = GREATER THAN OR EQUAL TO THE FOLLOWING NUMBER.

THIS DOCUMENT CONTAINS PROPRIETARY INFORMATION OF AVTRON MFG., INC. AND MAY NOT BE DISCLOSED TO OTHERS OR USED FOR MANUFACTURING PURPOSES WITHOUT THE WRITTEN CONSENT OF AVTRON MFG.



TITLE MODIFICATION, UL OUTDOOR, 500 KW, 480 VAC

CAGE NO. 01014	SIZE A	DRAWING NO. A28592	SH 4	OF 9	REV A
-------------------	-----------	-----------------------	---------	---------	----------

APPLICATION		REVISION				
MODEL/PART NO. MODIFIED	ECN	LTR	DESCRIPTION	DATE	APPROVAL	
K711-60-60-480F-5G-A,B,K	CD137	A	REV PER ECN	7/31/02	FACKELMANN K.KUK	

MODIFICATION REQUIRED

INSTALLATION INSTRUCTIONS (CONT.)

B.) IF LOAD CONTACTOR QUANTITY IS ≥ 6 TO ≤ 11 :

"INPUT BUS TORQUE REQUIREMENTS FOR AVTRON P/N 364973

LINE = 500 MCM THRU # 4 AWG = 375 IN. LBS.

LOAD = # 2 AWG THRU # 3 AWG = 50 IN. LBS.

= # 4 AWG THRU # 6 AWG = 45 IN. LBS.

= # 8 AWG = 40 IN. LBS.

= #10 AWG THRU #14 AWG = 35 IN. LBS.

USE COPPER, MINIMUM 75 DEGREE C WIRE"

C.) IF LOAD CONTACTOR QUANTITY IS ≥ 12 :

"INPUT BUS TORQUE REQUIREMENTS FOR AVTRON P/N 364924

LINE = 500 MCM THRU # 2 AWG = 425 IN. LBS.

LOAD = # 4 AWG THRU # 6 AWG = 35 IN. LBS.

= # 8 AWG = 25 IN. LBS.

= #10 AWG THRU #14 AWG = 20 IN. LBS.

USE COPPER, MINIMUM 75 DEGREE C WIRE"

3. INSTALL GROUND LUG, (P/N 366948) AT GROUND STUD AND ATTACH COMPUTER PRINTED LABEL (MATERIAL P/N 458519) NEXT TO GROUND LUG THAT READS AS FOLLOWS:

"TORQUE REQUIREMENTS FOR GROUND LUG - AVTRON P/N 366948

350 MCM THRU 250 MCM = 325 IN. LBS.

4/0 AWG THRU 3/0 AWG = 250 IN. LBS.

2/0 AWG THRU 1/0 AWG = 180 IN. LBS.

1 AWG THRU # 2 AWG = 150 IN. LBS.

4 AWG THRU # 6 AWG = 110 IN. LBS.

USE COPPER, MINIMUM 75 DEGREE C WIRE"

4. USE MOUNTING RAIL (P/N A17451-3) WITH COMPRESSION STYLE TERMINAL BLOCKS (P/N 364432) IN PLACE OF STRIP STYLE TERMINAL BOARD (P/N 364103) FOR TB1 ON THE LOAD BANK, AND THE REMOTE CONTROL PANEL.

THIS DOCUMENT CONTAINS PROPRIETARY INFORMATION OF AVTRON MFG., INC. AND MAY NOT BE DISCLOSED TO OTHERS OR USED FOR MANUFACTURING PURPOSES WITHOUT THE WRITTEN CONSENT OF AVTRON MFG.



TITLE MODIFICATION, UL OUTDOOR,
500 KW, 480 VAC

CAGE NO. 01014	SIZE A	DRAWING NO. A28592	SH 5	OF 9	REV A
-------------------	-----------	-----------------------	---------	---------	----------

APPLICATION		REVISION			
MODEL/PART NO. MODIFIED	ECN	LTR	DESCRIPTION	DATE	APPROVAL
K711-60-60-480F-5G-A,B,K	CD137	A	REV PER ECN	7/31/02	FACKELMANN K.KUK

MODIFICATION REQUIRED

INSTALLATION INSTRUCTIONS (CONT.) (SEE THE FIGURE ON THE FOLLOWING PAGE.)

5. MOUNT SWITCH BOOTS TO CONTROL PANEL SWITCHES.
6. INSTALL HOLE PLUGS IN LOAD BANK FRAME AS SHOWN.
7. LINE DRILL AND INSTALL HOOD USING 1/4-20 STAINLESS STEEL HARDWARE.
INSTALL GASKET MATERIAL BETWEEN ALL MATING SURFACES OF HOOD AND LOAD BANK.
8. ATTACH B15905 LABELS TO HOOD ON ALL THREE SIDES.
ATTACH LABEL A23206 BELOW ID TAG.
9. INSTALL GASKET MATERIAL ON VERTICAL MATING SURFACES BETWEEN CONTROL PANEL COVER AND FRAME, AND BETWEEN END COVER AND FRAME.
10. APPLY SILICONE SEALANT TO ALL HORIZONTAL MATING SURFACES OF THE FRONT COVER, END COVER, TOP, BOTTOM, AND SUPPORTS.
11. INSTALL SEAL WASHERS WHEN MOUNTING FRONT COVER.

THIS DOCUMENT CONTAINS PROPRIETARY INFORMATION OF AVTRON MFG., INC. AND MAY NOT BE DISCLOSED TO OTHERS OR USED FOR MANUFACTURING PURPOSES WITHOUT THE WRITTEN CONSENT OF AVTRON MFG.




TITLE MODIFICATION, UL OUTDOOR,
500 KW, 480 VAC

CAGE NO. 01014	SIZE A	DRAWING NO. A28592	SH 6	OF 9	REV A
-------------------	-----------	-----------------------	---------	---------	----------

APPLICATION		REVISION			
MODEL/PART NO. MODIFIED	ECN	LTR	DESCRIPTION	DATE	APPROVAL
K711-60-60-480F-5G-A,B,K	CD137	A	REV PER ECN	FACKELMANN 7/31/02	K.KUK

MODIFICATION REQUIRED



- 5 - SEAL WASHERS (PN 532739) TO BE USED ON TOP PANEL TO FRONT COVER ON K711 ONLY. (TOP OF UNIT)
- 4 - FILL UNUSED RESISTIVE ELEMENT HOLES WITH HOLE PLUGS. FILL UNUSED THERMOSTAT HOLE WITH ITEM 6; FILL UNUSED THERMOSTAT MOUNTING HOLES WITH STAINLESS STEEL HARDWARE.
- 3 - MOUNT SWITCH COVERS ON SWITCHES WHEN THERE IS AN INTEGRAL CONTROL PANEL MOUNTED ON LOAD BANK.
- 2 - ON ALL K711's ADD A BEAD OF SILICONE 910006 OR 910157 ALONG BOTH TOP EDGES, CONNECTION/CONTACTOR SIDE (FRONT & BACK) AFTER PANELS ARE INSTALLED, NOT ON CONTROL PANEL.
- 1 - ALL HARDWARE ADDED AT THIS LEVEL (EXCEPT PLUGS) TO BE STAINLESS STEEL.

THIS DOCUMENT CONTAINS PROPRIETARY INFORMATION OF AVTRON MFG., INC. AND MAY NOT BE DISCLOSED TO OTHERS OR USED FOR MANUFACTURING PURPOSES WITHOUT THE WRITTEN CONSENT OF AVTRON MFG.



TITLE MODIFICATION, UL OUTDOOR, 500 KW, 480 VAC

CAGE NO. 01014	SIZE A	DRAWING NO. A28592	SH 7	OF 9	REV A
-------------------	-----------	-----------------------	---------	---------	----------

APPLICATION	REVISION				
MODEL/PART NO. MODIFIED	ECN	LTR	DESCRIPTION	DATE	APPROVAL
K711-60-60-480F-5G-A,B,K	CD137	A	REV PER ECN	FACKELMANN	7/31/02 K.KUK

MODIFICATION REQUIRED

SCOPE: REPLACE DISTRIBUTION BLOCK WITH BUS BARS.

ASSEMBLY REQUIRED:

NOTE: THE INSULATORS MOUNTED IN STEP 1 MUST BE MOUNTED TO THE COMPONENT PANEL BEFORE IT IS RIVETED TO THE LOAD BANK FRAME.

1. MOUNT THE INSULATORS (P/N 411505) TO THE COMPONENT PANEL AS SHOWN ON PAGE 3. LINE DRILL AS REQUIRED. USE 3/8 INCH HARDWARE.

NOTE: THERE WILL BE NO LOAD STEP CONTACTOR OR FUSEBLOCK IN THIS LOCATION.

2. MOUNT THE BUSS BARS (P/N C24273) AND THE ASSOCIATED HARDWARE AS SHOWN ON PAGE 3. LABEL THE BUSS BARS AS A, B, AND C.

3. WIRE ALL THE FUSE CONNECTIONS NORMALLY CONNECTED TO THE DISTRIBUTION BLOCKS TO THE BUSS BARS.

4. INSTALL ID TAG (P/N A24032) ABOVE THE EXISTING ID TAG.

5. MODIFICATION COMPLETE.

THIS DOCUMENT CONTAINS PROPRIETARY INFORMATION OF AVTRON MFG., INC. AND MAY NOT BE DISCLOSED TO OTHERS OR USED FOR MANUFACTURING PURPOSES WITHOUT THE WRITTEN CONSENT OF AVTRON MFG.





TITLE MODIFICATION, UL OUTDOOR,
500 KW, 480 VAC

CAGE NO.	SIZE	DRAWING NO.	SH	OF	REV
01014	A	A28592	8	9	A

APPLICATION		REVISION				
MODEL/PART NO. MODIFIED	ECN	LTR	DESCRIPTION	DATE	APPROVAL	
K711-60-60-480F-5G-A,B,K	CD137	A	REV PER ECN	FACKELMANN	7/31/02	K.KUK

MODIFICATION REQUIRED

COMPONENT PANEL



THIS DOCUMENT CONTAINS PROPRIETARY INFORMATION OF AVTRON MFG., INC. AND MAY NOT BE DISCLOSED TO OTHERS OR USED FOR MANUFACTURING PURPOSES WITHOUT THE WRITTEN CONSENT OF AVTRON MFG.



TITLE MODIFICATION, UL OUTDOOR, 500 KW, 480 VAC

CAGE NO. 01014	SIZE A	DRAWING NO. A28592	SH 9	OF 9	REV A
-------------------	-----------	-----------------------	---------	---------	----------

AVTRON MODEL K711
LOAD BANK, RESISTIVE, DUCT MOUNT

Part Number K711-60-60-480F-5G-A,B,K
MODIFIED PER A28592
PROJECT NO. 251073

Load Bank Ratings:

Total KW 500 KW
Operating Voltage (Volts, Phase, Frequency, Amps) 480 VAC,
3 Phase, 60 Hz, 601.4 Amps.
Load Steps (KW) Five 100 KW Load Steps.
Minimum airflow required for full load operation 21,600 CFM

TABLE OF CONTENTS

<u>Section</u>		<u>Page</u>
I	SAFETY CONSIDERATIONS	1-1
II	DESCRIPTION AND SPECIFICATIONS	2-1
III	INSTALLATION	3-1
IV	OPERATION	4-1

DRAWINGS

<u>SB1635</u>	<i>Outline Drawing, Control Panel Enclosure.</i>
<u>SB2203</u>	<i>Outline Drawing, Load Bank</i>
<u>C23327</u>	Schematic/Wiring Diagram (Controls)
<u>C21408</u>	Schematic/Wiring Diagram, Load Bank

BULLETINS

202	Installation Notes, Engine Generator, Duct or Radiator Type
203	Sample Calculations, Engine Generator, Duct Type Load Banks

AVTRON MODEL K711
LOAD BANK, RESISTIVE, DUCT MOUNT
Serial Number 825 and Above

SECTION I

SAFETY CONSIDERATIONS

Throughout this manual, you will find **WARNING** and **CAUTION** statements. Personal injury to an operator using or repairing the equipment may occur if a **WARNING** statement is ignored. Damage to the equipment and potentially hazardous conditions for personnel may occur if a **CAUTION** statement is ignored.

Each Avtron unit is safety checked for opens and shorts, and the insulation is high potential tested to insure safe operation. All fuses, safety interlocks, and related safety equipment have been proven reliable as part of the testing procedure of each unit.

As part of your safety program, an initial inspection after receiving the unit(s) and periodic preventive maintenance and safety inspections should be conducted to insure the reliability and safety built into your Avtron equipment.

The Model K711 Load Bank is an industrial test unit designed to be used indoors safely. However, because of the nature of the Load Bank function (the dissipation of electrical energy), there are inherent dangers to operators and equipment. These dangers are outlined in this section.

Electrical energy is transformed into heat by the resistors. This heat must be removed from the Load Bank by the cooling blower (not part of Load Bank). If there is any restriction or stoppage of airflow, the Load Bank may overheat and may even start a fire. It is recommended that:

1. The operator should read the manual before using the Load Bank.
2. Run an approved ground wire from the Load Bank ground lug, located inside the load connection area to the generator frame. Run an approved ground wire from the generator frame to a good earth ground.

Safety Considerations

3. Your unit is equipped with a temperature switch in the load element area. Do not bypass the temperature switch to prevent nuisance tripping. The switch drops out load if insufficient air is reaching the load elements.
4. When installing the Load Bank, do not drill into side flanges. Use only top and bottom flanges as mounting locations. Compliance with this instruction helps guard against damage to internal wiring.
5. If the unit is to be installed within existing duct work, leave enough access area to easily remove access covers on each side of the Load Bank. Special consideration should be given to mounting surface material, duct and devices in close proximity due to hot air exhaust.
6. Connections to ducts must be watertight in outdoor applications.
7. Maintenance personnel must always exercise caution when the access panels are removed. Personal injury from electrical shock may result if all sources of power are not disconnected before servicing. Maintenance work must be done only by qualified personnel.
8. Adequate airflow in cubic ft./min. (CFM) must be maintained at all times. (Refer to the DESCRIPTION section for minimum value of required airflow.) Failure to maintain this airflow evenly across the resistor elements may result in element burnout. Indoor and enclosed units may require supplemental cooling air. Full load thermal testing should be conducted on initial run at maximum ambient to verify no cooling/thermal problems exist.
9. If duct work is vented through a screened exhaust or louvered exhaust, insure that the louvers (if motorized) are fully open when using the Load Bank. If exhausting through a screened opening, check screen periodically for any blockage. Screen needs to be a minimum 75% open area and at least as large as Load Bank core dimensions. The screen will add additional system resistance to airflow.
10. After running a load test, residual heat may be removed from the Load Bank and downstream duct work by allowing the blower to operate for a few minutes after loads are removed. This procedure is not required for Load Bank integrity, but it may guard operating personnel from possible burn injuries.
11. The operator should avoid coming in contact with the resistor elements or surrounding covers during and for some time after operation. These portions of the Load Bank become quite hot

Safety Considerations

and may result in a serious burn should contact be made with them.

12. Operators must not operate the Load Bank with the access panels or screens removed. To do so would expose the operator and other persons to possible personal injury from electrical shock.
13. An approved electrical fire extinguisher should be on hand at all times.
14. It is the responsibility of the customer to take diligent care in installing the Load Bank. The National Electrical Code (NEC), sound local electrical and safety codes, and the Occupational Safety and Health Act (OSHA) should be followed when installing the equipment to reduce hazards to persons and property.
15. Read and heed all **WARNING** and **CAUTION** statements in the manual.

SECTION II

DESCRIPTION AND SPECIFICATIONS

The Avtron Model K711 is designed to be used as a duct- or radiator-mounted Load Bank providing custom tailored mounting and installation. The K711 provides a resistive load rated as indicated on the Table of Contents. Minimum airflow required to cool the elements operating at full load is as indicated on the Table of Contents and must be maintained to insure safe operation of the Load Bank.

C A U T I O N

To prevent load element burnout, adequate airflow must be maintained over the entire load element area at all times voltage is applied. Insufficient air for even a few seconds will cause element burnout. This unit must have uniform airflow over the entire outlet area. If there are dead spots, damage to the elements may result.

CONTROL PANEL

The K711 Load Bank may be provided with a Control Panel as an option or the Control Panel may be customer supplied. The Control Panel may be supplied by Avtron in one of the following ways:

1. Factory installed on the side of the Load Bank without an enclosure.
2. Factory installed on the side of the Load Bank within an enclosure.
3. Factory installed within a remote mountable enclosure, separate from the Load Bank.

Description and Specifications

4. Factory supplied without an enclosure for remote mounting.

The Control Panel, when provided, serves as the manual control center for Load Bank operation. All load switches, safety indicator lights, and control circuit fuses are mounted on the panel.

When the Control Panel is not factory supplied, load application and safety circuitry are the responsibility of the customer.

Each K711 is designed with a relay compartment which contains load contactors, safety circuit components, optional load step fusing, optional control transformer with fuses, and a customer connection bus. If a Control Panel is not factory installed, the components in the relay compartment will require interconnection wiring during field installation of the Load Bank.

Interconnection wiring should conform to the National Electrical Code and any local codes.

AUTO TRANSFER SWITCH CAPABILITY

The load control circuitry is factory designed in such a way that remote operation with a customer-supplied transfer switch may be incorporated into the circuit. The factory control circuitry will be wired to a terminal board whereas a transfer switch must be enabled and connects at the terminal board per the schematic.

AUTOMATIC OPERATION

An Automatic Load Shed Controller (Controller) may be integrated into the control circuitry of the K711 Load Bank as an option. The Controller is designed to maintain a minimum load on a power source. A separately supplied current transformer provides the feedback signal required to operate the Controller. This feedback signal drives the Controller, which has field adjustable current setpoints. The Controller also incorporates field adjustable time delays to prevent repetitive load switching or initial overloading of the generator.

The Load Bank manual controls are paralleled by the automatic Controller. Automatic or manual mode may be chosen when the Load Shed option is provided with the Load Bank.

Description and Specifications

LOUVERS (OPTIONAL)

The exhaust of the Load Bank may be protected by either a stationary or motorized louver assembly. Due to exhaust temperatures, a stationary louver is the preferred option.

The motorized version would be added by end users and must include a limit switch which prevents the application of load steps if the louvers are not fully open. Verify louver and operating device are able to withstand exhaust temperatures before installation.




ESD PRECAUTIONARY GUIDELINES



C A U T I O N

Certain circuit card assemblies and their components, typically integrated circuits, may be damaged by seemingly undetectable electrostatic discharge (ESD). Care must be exercised during handling/repair of these items. Use electrostatic discharge precautionary procedures.

The following guidelines are not necessarily all inclusive but rather serve as reminders for good shop practices for the handling/repair of ESD sensitive circuit card assemblies and devices.

- Store ESD sensitive items in their original containers. These items are often marked with this symbol .
- Put on a grounded wrist strap before handling any ESD sensitive item.
- Clear work area of Styrofoam^{R*}, plastic, and vinyl items such as coffee cups.
- Handle ESD items by the body, never the open edge connectors.
- Never slide ESD sensitive items over any surface.
- Transport ESD sensitive items in a static shielding container to a static-free work station.
- If a static-free work station is not available, ground the transport container before removing or inserting an ESD item.
- Electric tools used during repair should be grounded. For example, use only anti-static type solder suckers and grounded tip soldering irons. Discharge non-electric tools before use.
- Pack ESD items in static shielding containers before shipping them to Avtron for repair.

*Styrofoam^R is a registered trademark of Dow Chemical.

SECTION III

INSTALLATION

This Load Bank is designed for direct installation in a ventilation duct or on the exhaust end of a radiator. Use standard 1/4 inch hardware to mount the Load Bank to the duct or radiator. This requires layout and drilling of the top and bottom flanges of the Load Bank at point of installation. Do not extend the hardware into the Load Bank more than a maximum of 1/2 inch to insure adequate clearance between element terminations and mounting hardware. Bulletin 202 shows the proper positioning of the Load Bank in the air duct.

CAUTION

To prevent load element burnout, adequate airflow must be maintained over the entire load element area at all times voltage is applied. Insufficient air for even a few seconds will cause element burnout. This unit must have uniform airflow over the entire outlet area. If there are dead spots, damage to the elements may result. Minimum uniform airflow velocity is 800 feet per minute. Recommended velocity is 1,000 feet per minute across entire load element area.

In general, the protection provided external to the Load Bank is determined by the local codes. Since the Load Bank is generally part of an existing electrical installation, it must be protected by a fused disconnect or circuit breaker meeting all local codes.

Before making any electrical connections, the maximum phase current for the Load Bank should be determined. This may be done using the following formula.

$$I_{\text{PHASE}}(\text{MAX}) = \frac{\text{KW} \times 577}{V \text{ (Line-to-Line)}}$$

C A U T I O N

When installing the Load Bank, do not drill into side flanges. Use only top and bottom flanges as mounting locations. Compliance with this instruction helps guard against damage to internal wiring.

The electrical connections necessary for proper operation of the Load Bank are as follows:

1. Connect the load power source as indicated on the Schematic/ Interconnection Diagram.
2. A ground connection must be made to the Load Bank (GND terminal) to prevent injury to personnel. This may be accomplished by a ground wire connected directly to the Load Bank ground stud provided in the control box. This ground wire should be connected to the frame of the generator under test. The generator frame should be grounded to a good earth ground.
3. Make control circuit connections as required using #14 AWG wire minimum. Refer to the Schematic Diagram found at the end of this manual for the required control voltage. For conduit runs greater than 50 feet, consult the factory.
4. When an automatic Controller is included with the Load Bank, installation of the current transformer on the main power bus as shown in Figure 3-1 is required. Wire the current transformer into the control circuitry as shown on the provided schematic.




FIGURE 3-1

Figure 3-1

W A R N I N G

Always put a short or shunt across the current transformer when servicing the Load Bank. Primary current flowing through an unshunted current transformer will destroy the transformer with possible harm to personnel.

Never allow the secondary of the current transformer to remain disconnected when primary current is passing through the transformer. If the Load Bank must be disconnected, put a short or shunt across the current transformer.

NOTE

Before placing the system into AUTO, place the Load Bank load step switch(es) to the OFF position.

OPTIONAL CONTROLLER OPERATION AND ADJUSTMENTS

W A R N I N G

Always put a short or shunt across the current transformer when servicing the Automatic Load Shed Controller. Primary current flowing through an unshunted current transformer will destroy the transformer with possible harm to personnel.

Before the current setpoint(s) can be adjusted, the operator must determine the maximum load the Controller should maintain (generally 60% to 80% of the total generator KVA).

SETPOINT CALCULATION (Example)

1. Generator Rating = 15 KVA at 240 VAC, 62.5 Amps
2. Setpoint Value (approximately 60% of Full Load)

$$\begin{aligned}\text{Setpoint} &= 15 \times 0.6 = 9 \text{ KW} \\ 9 \text{ KW at } 240 \text{ V} &= 37.5 \text{ Amps}\end{aligned}$$

TRIP POINT ADJUSTMENTS

There are three methods of field adjusting the trip point of the current sensing relays:

- Method 1 - Using generator load power
- Method 2 - Using a separate (0-5 Amp) current source without the current transformer
- Method 3 - Rough adjustment (Approximation Method)

Installation

METHOD 1 - Using the Actual Generator Load Power

This method uses the load current to set the current setpoint(s).

1. Apply 120 VAC, 60 Hz control power. (See schematic.) Place AUTO/MANUAL switch to MANUAL.

W A R N I N G

There is lethal high voltage present within the Controller enclosure; care must be taken when proceeding from this point.

2. On the Controller, turn the adjustable potentiometer, labeled LEVEL PERCENT, down to its lowest setting.
3. Energize the system while on line. Refer to the OPERATION instructions in Section IV.

NOTE

Always monitor the generator load with external metering so as not to overload the generator.

4. Adjust the generator load until the load equals the desired setpoint. The Load Bank can be used manually to achieve the desired load current if the current transformer is relocated to sense both building load and Load Bank load. Otherwise use actual building load.

NOTE

On the Controller, there is an LED indicator for each channel (Output). When lit, the channel is energized.

Channel 1 (LED CR13)
Channel 2 (LED CR17)
Channel 3 (LED CR21)
Channel 4 (LED CR25)
Channel 5 (LED CR29)

Installation

Turn the adjustable potentiometer, labeled LEVEL PERCENT, past the trip point (completely counterclockwise; LED is off). Then turn slowly clockwise until the channel trips on (LED is on).

METHOD 2 - Using a separate (0-5 Amp) Current Source without Current Transformer

1. Disconnect all sources of power to the Automatic Load Shed Controller.

W A R N I N G

When disconnecting the current transformer, the secondary terminals must be shorted. The secondary of an unshorted current transformer can exceed several thousand volts.

2. Apply 120 VAC, 60 Hz control power. (See schematic.)

W A R N I N G

There is lethal high voltage within the control enclosure.

3. Using a controlled current source, apply the setpoint current (from secondary current calculation) to Controller terminals J1-1 and J1-2.
4. Turn the adjustable potentiometer, labeled LEVEL PERCENT, counterclockwise past the trip point; then decrease until the channel trips on, indicated by LED turning on.

Installation

METHOD 3 - Rough Adjustment

Use the following formula to calculate the percentage C.T. Tap chosen to operate the P.C. Board:

$$\% \text{ Dial Setting} = \text{Setpoint}/\text{C.T. Tap}$$

**INSTALLATION CHECKOUT PROCEDURE -
TO BE DONE PRIOR TO OPERATION**

This Installation Checkout Procedure is intended to be used upon initial receipt of equipment and following any relocation of a permanent mounted Load Bank. These procedures apply to Load Banks in general and may include steps not relevant to the specific unit being installed. Disregard those procedures which do not apply.

W A R N I N G

THE FOLLOWING TESTS ARE TO BE ACCOMPLISHED BY A QUALIFIED ELECTRICIAN OR TECHNICIAN USING EXTREME CAUTION AS POTENTIALLY LETHAL VOLTAGES AND DANGEROUS ROTATING COMPONENTS ARE PRESENT. IF ASSISTANCE IS REQUIRED, AVTRON CAN PROVIDE START UP SERVICE AT A NOMINAL CHARGE. AVTRON ALSO WILL PROVIDE TELEPHONE ASSISTANCE IF REQUIRED BY CALLING (216) 641-8310.

1. Verify the Load Bank placement meets the installation requirements found in the Installation section of the instruction manual:
 - A. Check the clearance from both intake and exhaust to any obstruction.
 - B. If the location has a prevailing wind, make the wind aid in the cooling of the resistor elements.
 - C. If the Load Bank is elevated, a plate under the Load Bank will be needed to block hot exhaust from returning to the intake.

Installation

2. Check the mechanical integrity of all customer-supplied interconnection wiring:
 - A. Check lugs that they are properly crimped.
 - B. Check terminations that they are properly torqued.
3. Utilize system schematics to ohm out customer-supplied interconnection control wiring and safety circuits:
 - A. If control wiring is all the same color, ohm out each individual wire to confirm proper labeling and placement.

C A U T I O N

Control wiring must be a minimum of 14 AWG for wire runs under 50 feet. Consult Avtron factory for wire sizing when wire run exceeds 50 feet.

- B. Confirm the correct wire gauge has been used for interconnection wiring. Control wiring should be a minimum of 14 AWG for control panel to Load Bank lengths of 50 feet or less. For lengths greater than 50 feet, consult the factory.
- C. If a Control Transformer is the source of control power, disconnect the control transformer before proceeding.

C A U T I O N

When control power is supplied by a transformer within the Load Bank, it must be disconnected before running this installation checkout procedure. Failure to disconnect the control transformer may damage the Load Bank.

4. Energize the source of control power only. Check the control voltage and confirm it is within 10% of the required voltage.

W A R N I N G

Control power is present on terminal block in steps 4 through 6.

5. Verify the proper relays energize with each individual load switch.
 - A. Turn on each load step individually and observe that each relay or relays pulls in without chatter or hesitation.
 - B. Turn off the master load switch. Turn on all the load steps. Turn the master load on and observe the pull in of all the contactors. If chatter or hesitation is observed, locate the cause of the voltage drop causing the problem.

6. Apply the rated fan voltage. Start blower and verify that air is exiting the resistor assembly end.

This checkout procedure is intended to be a guide to Load Bank installations in general. Special installation considerations not addressed herein may be necessary due to installation site or environment. Any questions or concerns regarding Load Bank installation should be directed to Avtron Field Service at (216) 641-8310.

SECTION IV

OPERATION

C A U T I O N

DO NOT operate the Load Bank over the rated voltage as this will cause a catastrophic failure in the Load Bank.

DO NOT apply DC voltages to the Load Bank because the contactors do not have arc blowout magnets.

To prevent load element burnout, adequate airflow must be maintained over entire load element area at all times voltage is applied. Insufficient air for even a few seconds will cause element burnout.

It is important to note that if the generator is removed, the control circuit may still be energized if control power is not removed. Therefore, before removing cover, make certain all sources of power to the Load Bank are disconnected.

The K711 Load Bank may be operated in a manual mode or, if the Load Shedder option is provided, in an automatic mode. Operation instructions for the different modes are as follows:

1. Manual Operation - K711 units without a Control Panel.
2. Manual Operation - K711 units with a Control Panel included as an option.
3. Automatic Operation - K711 units with the Load Shedder option.

Operation

Take note that in cases where the K711 Load Bank is provided with the transfer switch option, to permit load application, the terminal board terminals referenced on the schematic for this application must be connected either by a hard wired jumper or a closed transfer switch contact.

MANUAL OPERATION (for K711 units without a Control Panel)

After mounting the K711, connecting 120 V control power, and running interconnecting control wires per the schematic:

1. Check to confirm that all load contactors will not be energized prematurely.
2. Connect generator or other source to be tested to the Load Bank as described in the INSTALLATION section.
3. Apply power to the control circuit. (If Load Bank has motorized louvers, verify louvers are open prior to the initiation of airflow.)
4. Start power source under test. Be sure air is flowing over resistance elements.
5. Apply load to the power source by energizing load contactors.
6. Shutdown - After running a load test, residual heat may be removed from the Load Bank and downstream duct work by allowing the blower to operate for a few minutes after loads are removed. This procedure is not required for Load Bank integrity, but it may guard operating personnel from possible burn injuries.

MANUAL OPERATION (for K711 units with a Control Panel included as an option)

After mounting the K711, connecting 120 V control power, and running interconnecting control wires per the schematic:

1. Place all switches on the Control Panel to the OFF position.
2. Place AUTO/MANUAL switch to MANUAL. (This step only applies to Load Banks with Load Shedder option.)
3. Connect the generator or other power source to be tested to the Load Bank as described in the INSTALLATION section.

Operation

4. Place the POWER switch to the ON position. The POWER light will be energized indicating control power is present. (If Load Bank has motorized louvers, verify louvers are open prior to the initiation of airflow.)
5. With the MASTER LOAD switch in the OFF position, start the generator under test. Using a customer-supplied blower, be sure air is flowing over the resistance elements.
6. The resistive loading is selected by load step switches, using any one or a combination to make up a given load.
7. Apply load to the power source by moving the MASTER LOAD switch to the ON position.
8. Any load can be added or removed during MANUAL testing provided the MASTER LOAD switch is on.
9. To remove all loads, move MASTER LOAD switch to the OFF position.
10. Shutdown - Place all switches in the OFF position. After running a load test, residual heat may be removed from the Load Bank and downstream duct work by allowing the blower to operate for a few minutes after loads are removed. This procedure is not required for Load Bank integrity, but it may guard operating personnel from possible burn injuries.

AUTOMATIC OPERATION (for K711 Load Banks with Load Shedder option)

After mounting the K711 and connecting 120 V control power per the schematic:

1. Place all switches on the Control Panel to the OFF position.
2. Connect the generator or other power source to be tested to the Load Bank as described in the INSTALLATION section.
3. Place the POWER switch to the ON position. The POWER light (DS1) will be energized, indicating control power is present. (If Load Bank has motorized louvers, verify louvers are open prior to the initiation of airflow.)
4. Place AUTO/MANUAL switch to AUTO.
5. Start the generator under test. Using a customer-supplied blower, be sure air is flowing over the resistance elements.


Operation

6. When the Auto Transfer Contact is open, the Auto Load Shedder will be active. As the load on the generator lessens, the Load Shed Controller will automatically apply load steps until the overall generator load exceeds the minimum setpoint. The Load Shed Controller automatically removes load steps when the generator load exceeds the maximum setpoint.

DRAWINGS

PROPRIETARY NOTE

The wiring diagrams and schematics which follow contain information PROPRIETARY to Avtron Manufacturing, Inc., are furnished solely to provide information sufficient for instruction, operation, maintenance, evaluation, and testing of the equipment herein disclosed, are not to be used for manufacturing or procurement and are not to be disclosed to anyone other than persons in the Division, or the Company, or the Government, as the case may be, responsible for action relating to this document without the express written permission of Avtron Manufacturing, Inc.



FOR APPLICATION ENGINEERING USAGE ONLY

THIS DOCUMENT CONTAINS PROPRIETARY INFORMATION OF AVTRON MFG. INC. AND MAY NOT BE DISCLOSED TO OTHERS OR USED FOR MANUFACTURING PURPOSES WITHOUT THE WRITTEN CONSENT OF AVTRON MFG.

CONVERTED CAD FILE & STANDARDIZED WITHOUT CHANGE


MARTIN PALUMAS
CHKD

DATE: 2/4/86
DRAWN: BW
CHECKED: RJS
APPROVED: RJS
SCALE: 1/4

AVTRON MANUFACTURING, INC.
INDEPENDENT, DE
ENCLOSURE,
WALL MOUNT

DRAWING NUMBER: SB1635
OUTLINE DRAWING

2. ALL DIMENSIONS ARE APPROX.
1. WEIGHT:
NOTES:



CONTROL PANEL

IF OPTION "A" IS SUPPLIED WITH LOAD BANK THE CONTROL PANEL IS NOT INSTALLED ON LOAD BANK IN THIS LOCATION. IT IS PROVIDED AS A REMOTE 19" RACK MOUNT COMPONENT.

POWER DISTRIBUTION BLOCK

3 - K711 LOAD BANKS, WITH OUTDOOR UL OPTION, USE A HOOD IN PLACE OF LOUVER. THE HOOD DEPT WILL CHANGE THE 5.50 DIMENSION TO "H" OR THE SAME AS THE HEIGHT OF THE CORE.

2. ALL DIMENSIONS ARE APPROX.

1. WEIGHT:

NOTES:


ENGINEERING USAGE ONLY

MANUFACTURING, INC. INDEPENDENCE, OH	DRAWING NUMBER SB2203
BANK 1	OUTLINE DRAWING

THIS DOCUMENT CONTAINS PROPRIETARY INFORMATION OF AVTRON. IT IS TO BE USED ONLY FOR THE PURPOSES FOR WHICH IT WAS DESIGNED AND IS NOT TO BE REPRODUCED OR TRANSMITTED IN ANY FORM OR BY ANY MEANS WITHOUT THE WRITTEN CONSENT OF AVTRON MFG.

ECN NO.	REV.	DESCRIPTION	DATE	APPROVED
ADR48	A	REVISED PER ECH	7/23/97	ARMAGOSTI
CA932	B	REVISED PER ECH	7/29/97	HUDSON
CA932	C	REVISED PER ECH	9/23/98	HUDSON
CB445	D	REVISED PER ECH	12/22/98	K.KUK
CC082	E	AUTO/MAN SWITCH DS50 WAS DESG. MURA	2/18/00	K.KUK
CC465	F	DS50 WAS POWER ON	1/3/01	K.KUK
CC693	G	NEW WIRING FOR 240V CONTROL TRANSFORMER PER ECH	5/29/01	K.KUK

ECN NO.	REV.	DESCRIPTION	DATE	APPROVED
CD122	J	DS50 WAS DESIG FOR ITEM 6. J.F. LAUTO	5-9-02	K.KUK
	J	ADDED NOTE NEXT TO TB2(5)	7-16-02	K.KUK



DESIG.	PART NO.	DESIG.	PART NO.	DESIG.	PART NO.	DESIG.	PART NO.	DESCRIPTION	MATERIAL
SI-21	360589	SI-21	360589	SI-21	360589	SI-21	360589	SWITCH, TOGGLE	
S50	360591	S50	360591	S50	360591	S50	360591	SWITCH, TOGGLE	
A101	A22829	A101	A22829	A101	A22829	A101	A22829	PC BOARD ASSY. LOAD SHED	
P1,P2	364457	P1,P2	364457	P1,P2	364457	P1,P2	364457	CONNECTOR, SOCKET	
S60	360379	S60	360379	S60	360379	S60	360379	SWITCH, TEMPERATURE	
TB2	364054	TB2	364054	TB2	364054	TB2	364054	TERMINAL BOARD	
TB1	364103	TB1	364103	TB1	364103	TB1	364103	TERMINAL BOARD	
DS20,DS50	329715	DS20,DS50	329715	DS20,DS50	329715	DS20,DS50	329715	LIGHT, INDICATOR (GREEN)	
DS21	329714	DS21	329714	DS21	329714	DS21	329714	LIGHT, INDICATOR (RED)	
XF101	325022	XF101	325022	XF101	325022	XF101	325022	FUSEHOLDER	
XF102,XF103	324615	XF102,XF103	324615	XF102,XF103	324615	XF102,XF103	324615	FUSEBLOCK	
F101	324128	F101	324128	F101	324128	F101	324128	FUSE	
F102,F103	324452	F102,F103	324452	F102,F103	324452	F102,F103	324452	FUSE	
T1	370849	T1	370884	T1	370884	T1	370855	TRANSFORMER	

LIST OF MATERIAL	DATE	SCALE	NO. OF SHEETS
208V	9/26/96	1/4"	1 OF 1
240V	9/27/96	1/4"	1 OF 1
480V	9/27/96	1/4"	1 OF 1
600V	9/27/96	1/4"	1 OF 1

UNLESS OTHERWISE SPECIFIED THE ABOVE NOTES APPLY TO ALL UNITS.

UNITS WITH A REMOTE CONTROL PANEL (OPTION A) WILL HAVE A 'TBI' ON BACK OF PANEL AND AT LOAD BANK. CUSTOMER TO WIRE INTERCONNECTION UNITS WITH LOCAL CONTROL PANEL WILL HAVE FACTORY WIRING BETWEEN LOAD BANK TBI AND CONTROL PANEL COMPONENTS.

7 - ALL WIRING TO BE #16AWG (P/N 398008). ALL WIRING TO BE BLACK UNLESS NOTED OTHERWISE.

8 - T1, F102, F103 ARE USED ONLY FOR UNITS WITH OPTIONS H, JK OR L.

9 - DS50, DS51, TB2 & A101 ARE USED ONLY FOR UNITS WITH OPTIONS C,D,E OR F.

10 - FOR 208V UNITS FOR 600V UNITS S50VA

11 - FOR 240V UNITS FOR 240V UNITS S50VA

12 - J* - REMOVE THIS WIRE TO ALLOW AUTO OPERATION. (ON UNITS WITH OPTIONS C,D,E OR F)

13 - J** - REMOVE THIS WIRE FOR LOAD DUMP OPERATION.

14 - DASHED LINES INDICATE OPTIONAL WIRING.

15 - GOLD DASHED LINES INDICATE CUSTOMER WIRING.

16 - N/A = NOT AVAILABLE

17 - 3 -

18 - 2 -

19 - 1 -

20 - UNLESS OTHERWISE SPECIFIED THE ABOVE NOTES APPLY TO ALL UNITS.


ECN NO	REV	DESCRIPTION	DATE	APPROVED
Z9625	E	PROGRAM ADDED NOTE 5.	12-15-93	D. BOHRER
Z9948	F	REV PER ECN	ZYNKOVIC 7/6/94	D. BOHRER
ACS33	G	ADDED BUBBLE 6	GILLISSIE 3/78/96	D. BOHRER
CS109	H	REMOVED ITEM 10 FROM BOM PER ECN UPDATED SCHEM - ITEM 6 BETWEEN 4 & 9 - WAS 10.	RT/DOLO 04/20/99	K. KUK

LOAD STEP CONFIGURATION GUIDE
EXAMPLE PART NO.:
K711-26-30-480W-A2BC-A,B

THIS DEFINES THE
LOAD STEP CONFIGURATION AS
A = 1 LOAD STEP OF 5KW
B = 2 LOAD STEPS OF 10KW
C = 1 LOAD STEP OF 15KW
PER KEY
BELOW

APPLY THE ABOVE EXAMPLE TO ACTUAL
PART NO. OF ANY MODEL K711 LOAD BANK.
REFER TO MATERIAL TABULATION AND THE
APPLICABLE LOAD STEP DIAGRAM FIGURE.

LETTER	LOAD STEPS
A	5KW
B	10KW
C	15KW
D	20KW
E	25KW
F	50KW
G	100KW
H	200KW
J	400KW



THIS IS REFERENCE INFORMATION, PARTS AND TOTAL QUANTITIES ARE SPECIFIED ON THE MFG TOP ASSEMBLY DRAWING.

SEE POWER DISTRIBUTION BLOCK CHART										
NR	NR	NR	NR	NR	NR	NR	NR	NR	NR	10
FIG.#1	FIG.#1	FIG.#1	FIG.#1	FIG.#1	FIG.#1	FIG.#1	FIG.#1	FIG.#1	FIG.#1	POWER DISTR BLOCK
AR 390323	AR 390323	AR 390322	AR 390322	AR 390321	AR 390735	AR 390735	AR 390736	AR 390736	AR 390736	9 RESISTOR
1 324967	1 324967	1 324660	1 324660	1 324977	1 324977	1 324977	1 324977	1 324977	1 324977	8 RESISTOR
3 324420	3 324420	3 324419	3 324419	3 324742	3 324742	3 324742	3 324742	3 324742	3 324742	7 LOAD STEP DIAGRAM
8 602050	8 602050	8 602050	8 602050	8 602050	8 602050	8 602050	8 602050	8 602050	8 602050	6 WIRE (BLACK)
1 814796	1 814796	1 814795	1 814795	1 814795	1 814795	1 814795	1 814795	1 814795	1 814795	5 FUSE/BLOCK
6 606337	6 606344	6 606337	6 606344	6 606338	6 606346	6 606346	6 606346	6 606346	6 606346	4 FUSE
QTY P/N	QTY P/N	QTY P/N	QTY P/N	QTY P/N	QTY P/N	QTY P/N	QTY P/N	QTY P/N	QTY P/N	3 BUS LINK
50KW STEP	50KW STEP	25KW STEP	25KW STEP	20KW STEP	20KW STEP	15KW STEP	10KW STEP	10KW STEP	10KW STEP	2 RELAY
W >39	27<W<39	27<W<35	27<W<35	27<W<35	27<W<35	27<W<35	27<W<35	27<W<35	27<W<35	1 RESISTOR
										DESCRIPTION

POWER DISTRIBUTION BLOCK
(REF: CHART 3 ON TOP ASSY)

TOTAL RELAYS USED AS INDICATED IN TOP ASSEMBLY (Y COLUMN)	(ITEM 9) POWER DISTRIBUTION BLOCK	QTY
1 THRU 5	364948	1
6 THRU 11	364973	1
12 THRU 29	364979	3

CONFIGURATION AND QUANTITY OF LOAD STEPS ARE DEFINED BY PART NUMBER CODE.

- 100KW STEP - USE 50KW COLUMN x 2
- 200KW STEP - USE 50KW COLUMN x 4
- 400KW STEP - USE 50KW COLUMN x 8

6 - ITEM 3 MAY BE REPLACED BY #6 AWG JUMPER WIRE (PN 390323).

5 - EACH COLUMN DEFINES MATERIAL REQUIRED FOR ONE LOAD STEP.

4 - ITEMS #4 AND #5 READ ONLY IF DIGIT #12 OF LOAD BANK PART NUMBER IS F.

3 -

2 -

1 -

UNLESS OTHERWISE SPECIFIED THE ABOVE NOTES APPLY

THIS DOCUMENT CONTAINS PROPRIETARY INFORMATION OF AVTRON. IT IS TO BE KEPT CONFIDENTIAL AND NOT REPRODUCED OR USED FOR MANUFACTURING PURPOSES WITHOUT THE WRITTEN CONSENT OF AVTRON MFG.

AVTRON MANUFACTURING THE PERFORMANCE OF 4413-5609
2000 PLEASANT VALLEY ROAD
WILMINGTON, MA 01897

DATE: 6/12/92
DRAWN: ZAKCEK
CHECKED: []
ENG APP'D: D. BOHRER
APP'D PROD: G. MELISA

UNLESS OTHERWISE SPECIFIED DIMENSIONS ARE IN INCHES. DECIMALS, 244. ANGLES ± .004.

FINISH: PAINT PER PS. PLATE PER PS. COAT PER PS. ANODIZED PER OTHER.

APPLICATOR: K711
USED ON: K711
NEXT ASSY: []

UNLESS OTHERWISE SPECIFIED DIMENSIONS ARE IN INCHES. DECIMALS, 244. ANGLES ± .004.


SCALE: NAME MODEL K711

REV H
C21408
DWG. NO. C21408
CASE NO. 01014
DATE 04/20/99


SHEET 1 OF 1

Since the load banks absorb 100% of their rating as soon as voltage is applied regardless of air flow, it is necessary to install them properly to prevent damage or malfunctions. Outlined below are some practices which should be followed.

- AIR FLOW** - The air flow through all sections of the load bank should be at least 800 ft/min. and preferably 1000 ft/min. or greater. The air flow should not be blocked from some sections of the load bank or the load bank installed so there are areas of "dead" air. See Bulletin 203 for method of air flow computation. Elevation view is shown below. Similar layout in plan view except allow approximately 18" beyond duct or core dimensions for control area. See outline drawing.




RIGHT




RIGHT

(PREFERRED IF OVERSIZED
 LOAD BANK IS REQUIRED)




WRONG



RIGHT

LOAD
 ELEMENT



WRONG

★ Rev. 7/25/00

BULLETIN 202
INSTALLATION NOTES
ENGINE GENERATOR DUCT
TYPE LOAD BANKS
Page 2 of 2

2. **ELEMENT POSITION** - The elements are designed for horizontal installation to prevent sagging or movement that would cause damage. The load bank should be installed with the elements horizontal, as shown above.
3. **RATED CURRENT AND FUSING** - When installing the load bank, it is necessary to provide the proper size wire and, if fuses are required, they must be selected so they are compatible with the load steps and voltage applied to the unit. The current drawn by the load bank may be computed from the formula:

$$I = \frac{KW \times 577}{\text{Voltage (Line-to-Line)}}$$

For example, a 100 KW load bank will draw 120 amperes at 480 volts and 240 amperes at 240 volts. For the low voltage installation, the fuse rating and wire size must have twice the current capacity of the high voltage installation. Load banks can be installed with a load connected as a single step or multiple small steps, and the fuses and wire size should be selected accordingly.

4. **PARTIAL DUCT INSTALLATIONS** - There may be installations where only a small amount of load is required relative to the generator rating and duct size. Avtron recommends that a load bank be selected which is large enough to match the size of the engine air duct. If this is not feasible, a smaller load bank can be used which will only fill a part of the duct. Under these circumstances, it is the installer's responsibility to insure that sufficient air passes through the load bank for proper cooling.
5. **INSTALLATION NOTES FOR UNITS OVER 50" WIDE** - Units over 50" wide have a full perimeter frame which matches design size (duct or radiator core width). A secondary fixed internal load element support panel is used in these widths. As long as uniform air flow of at least 800 ft./min. is provided across load elements, no problems should occur. However, cooling loss may occur due to air flow around load elements and through open area. In these rare cases, it may be necessary to add a baffle or similar device to direct air flow. Consult Avtron for design support in these cases.

I. AIRFLOW CALCULATIONS

Load Banks are designed to operate with air passing over the load elements at a rate of approximately 1,000 ft./min. (5.08 meters/sec.). They will withstand higher air velocity without any problems as far as the Load Bank is concerned; however, the pressure drop across the Load Bank will increase. Therefore, this must be considered when selecting a Load Bank. When the air velocity is a great deal less than 1,000 ft./min., the load elements will operate at a higher temperature, which results in shorter life. At very low air velocity, the elements will overheat and be destroyed. The minimum uniform air velocity is 800 ft./min. across load element area.

Outlined below are simple methods of computing air velocity, pressure drop, and temperature rise for the Avtron K711 series duct type Load Banks.

A. AIR VELOCITY COMPUTATIONS

When selecting a duct type Load Bank, the engine radiator parameters such as size and airflow are known. The Load Bank frame with dimensions closest to the effective dimensions of the radiator should be considered. For a given engine configuration, the airflow in cubic feet per minute or liters per second is supplied by the engine manufacturer. The velocity is calculated by using the effective area of the Load Bank and the engine airflow.

$$\text{Velocity (Ft. per Min.)} = \frac{\text{Engine Airflow (cu. ft./min.)} \times 144}{\text{Load Bank Width (in) Load Bank Height (in)}}$$

$$\text{Velocity (meters/sec.)} = \frac{\text{Engine Airflow (Liters/Sec.)} \times 10}{\text{Load Bank Width (cm) Load Bank Height (cm)}}$$

B. PRESSURE DROP

The Avtron K711 series of Load Banks are designed to be compatible with typical radiator sizes and airflows. One important criterion in application of the Load Banks is the air pressure drop through the Load Bank. The engine generator sets are usually designed with sufficient fan capacity to provide a head of .5 in. H₂O (12.7mm H₂O) after the air has passed through the radiator. The Load Banks are designed to minimize the cooling air pressure drop. Typically, the louver type Load Banks have a pressure drop of about .2 in. H₂O (5.08mm H₂O) and the duct types have a drop of about .1 in. H₂O (2.54mm H₂O) at minimum rated airflow.

★ Rev. 7/25/00

AVTRON MANUFACTURING, INC.

Style K711A units have slightly higher pressure drops. Consult Avtron for calculated system resistance. Verify air handling system can tolerate additional pressure drop and maintain at least 800 ft./min. across load elements.

C. AIR TEMPERATURE RISE

In some installations, the allowable exhaust air temperature from the overall engine generator and Load Bank combination must be limited to a specific value. The temperature rise information on the engine generator combination can be supplied by the manufacturer. The air temperature rise through the Load Bank can be calculated from the following formula:

$$\text{Temp Rise (° F)} = \frac{\text{Load Bank KW} \times 3200}{\text{CFM}}$$

$$\text{Temp Rise (° C)} = \frac{\text{Load Bank KW} \times 570}{\text{Liters/Sec.}}$$

Depending on the installation, the cooling system exhaust air temperature rise may be compiled using the Load Bank temperature rise derived from the above calculation and adding it to the other system temperature rises.

NOTE

This is average air temperature rise. Parcels of air will significantly exceed this number. Areas with lower velocity will operate at higher temperatures.

II. ELECTRICAL CALCULATIONS

A. RATING

The Load Bank power ratings are based on the highest rated operating voltage. Each load step consists of two elements, each rated at 138 volts connected in wye. When connected in the series configuration, the Load Bank may be used on 480V or 380V, 3 Phase. With 480 volts applied to the terminals, 138 volts is applied to each element. When connected in parallel configuration, the Load Bank may be used on 240V or 208V, 3 Phase systems. With 240V, 3 Phase applied to the terminals, 138 volts is applied to each element. The load absorbed by the Load Bank at other than rated voltage can be computed from the formula:

$$\text{Absorbed KW} = \frac{\text{Rated KW} \times (\text{Applied Voltage})^2}{(\text{RATED VOLTAGE})^2}$$

For example, a 100 KW Load Bank connected for 240 volts with 208 volts applied will absorb 75 KW.

$$\text{Absorbed KW} = \frac{100 \times (208)^2}{(240)^2}$$

B. CURRENT CALCULATIONS

To determine the wire size and fuse ratings for a given installation, it is necessary to determine the line current. This can be readily determined from the formula:

$$\text{Phase Current} = \frac{\text{Absorbed KW} \times 577}{\text{Applied Voltage (Line-to-Line)}}$$

For example, a 100 KW load with 480 volts applied will draw 120 amperes per phase.

$$\text{Phase Current} = \frac{100 \times 577}{480}$$

C. REACTIVE LOAD CALCULATIONS

When engine generator sets are operated with Resistive (KW) load, they are being tested at unity (1.0) Power Factor. Some load tests require operation at lower power factors, usually .8 PF. To perform these tests requires a load with both Resistive (KW) and Reactive (KVAR) capability. The Resistive and Reactive parts of the total load add vectorially, not directly. For example, to load a 100 KW generator at .8 Power Factor requires a Resistive load with a capacity of 100 KW and a Reactive load of 75 KVAR. The total load (Resistive and Reactive) on the generator is expressed as Volt-Amperes (KVA) and is the product of current times voltage. Using the above example of 100 KW Resistive load and 75 KVAR Reactive load, the total load (KVA) on the generator is 125 KVA.

Rev. 7/25/00



When the generator set rating is expressed in terms of Resistive load at a certain power factor (100 KW at .8 PF), the total load (KVA) and Reactive load (KVAR) can be calculated as outlined below.

$$\text{Total Load (KVA)} = \frac{\text{Resistive Load (KW)}}{\text{Power Factor}}$$

$$\text{KVA} = \frac{100}{.8} = 125$$

$$\begin{aligned} \text{Reactive Load} &= \sqrt{(\text{KVA})^2 - (\text{KW})^2} \\ &= \sqrt{(125)^2 - (100)^2} \\ &= \sqrt{15625 - 10000} \\ &= \sqrt{5625} = 75 \text{ KVAR} \end{aligned}$$

Warranty

Warranty and Duration

For a period of one year after installation, or fifteen (15) months from date of shipment from our plant, whichever is shorter, Avtron warrants the equipment, except as hereinafter provided, to be free from harmful defects in material and workmanship. Notwithstanding any other term or provision in this Warranty, the warranty provided herein shall terminate unless buyer notifies Avtron, in writing, of a breach hereof within the warranty period; any claims not made within such period are waived by Buyer. The warranty provided herein applies only if Buyer complies with all the other terms and provisions of this Warranty.

Uses of Equipment

The warranty provided herein applies only if the equipment has been used in a normal and proper manner under recommended conditions. Notwithstanding any advice or assistance given to the Buyer by Avtron or its suppliers concerning the equipment or its use, Avtron makes no express or implied warranties or representations, except as herein expressly provided, with respect to the equipment or its use, and Avtron shall not be liable in contract, warranty or tort (including, without limitation, for negligence or strict liability) as a result of such advice or assistance. In addition, unless otherwise agreed in writing signed by a duly authorized representative of Avtron, no equipment covered by this warranty is intended to be used in connection with any nuclear facility or activity, and if so used, Avtron disclaims any and all liability for any damage resulting therefrom.

Notification of Breach

When claiming a breach of this Warranty, Buyer must promptly (within 10 days from the date of the discovery of the defect) notify Avtron in writing.

Equipment Disposition

Upon notification of a claimed breach of this Warranty, Avtron, at its discretion, will either authorize the return of the defective equipment or part thereof (transportation costs to be prepaid by Buyer) or provide a suitable replacement or authorize the Buyer in writing to effect repairs at Avtron's expense. In the event that the equipment returned as authorized is found to be defective and Avtron elects to repair or replace said equipment, Avtron will pay the transportation costs associated with the return of said equipment to Buyer. Avtron shall not however be liable for any customs, tariffs, duties or taxes incurred in shipping equipment pursuant to this Warranty. These shall be the responsibility of the Buyer.

Option of Avtron to Repair or Replace Equipment or to Issue Credit

Avtron's sole obligation under this Warranty shall be, at the option of Avtron, to replace or repair any defective equipment or part thereof or to issue a credit with respect to the defective equipment equal to the purchase price thereof less depreciation.

Equipment Excluded From Warranty

The warranty provided herein specifically excludes equipment and components that Avtron purchases and resells as part of a system, product or spare part order. The warranties provided to Avtron by the manufacturers of the foregoing equipment and components will, to the extent possible, be passed on to the Buyer. Copies of such warranties, if on file at Avtron, will be made available for inspection upon the request of Buyer. Equipment such as, but not limited to, computers, CRTs, operator interface modules, monitors, etc., normally have a short warranty period and should be covered by a continuous service contract generally available from the original manufacturer at a reasonable cost. Consumable items including, but not limited to, lamps, filters, fuses and motor brushes are excluded from all warranties. Other items or components may be excluded from this warranty if so noted in the governing purchase order or contract.

Resale or Lease of Equipment

In the event that the Buyer resells or leases equipment purchased from Avtron, the Buyer shall obtain the signed written agreement of the purchaser or lessee thereof that Avtron's only liability with respect to said equipment is as set forth in this Warranty. In the event that the Buyer fails to obtain such a signed written agreement, the Buyer agrees to indemnify Avtron against any claims, demands, judgments, suits, costs, liabilities and expenses (including reasonable attorney's fees) incurred by Avtron as a result of such failure.

Unauthorized Repairs

Unless otherwise agreed in writing signed by a duly authorized representative of Avtron, if the Buyer has repairs or modifications made to equipment covered by this Warranty by a person other than an authorized Avtron service representative, Avtron shall not be liable for any expenses incurred in connection therewith and the warranty provided herein shall automatically be terminated.

Governing Law; Saving Clause

This Warranty is part of the terms and conditions of the sale of the equipment covered hereunder and shall be governed by and enforced in accordance with the laws of the State of Ohio. Any provision hereof which is prohibited or unenforceable in any jurisdiction shall, as to such jurisdiction, be ineffective to the extent of such prohibition or unenforceability without invalidating the remaining provisions hereof or affecting the validity or enforceability of such provision in any other jurisdiction.

Limitation of Liability

IN NO EVENT SHALL AVTRON BE LIABLE IN CONTRACT, IN TORT OR OTHERWISE FOR SPECIAL, INCIDENTAL, CONSEQUENTIAL OR PUNITIVE DAMAGES (INCLUDING, BUT NOT LIMITED TO, LOSS OF PROFITS OR REVENUES, LOSS OF USE OF THE EQUIPMENT OR ANY DAMAGE TO ASSOCIATED EQUIPMENT, DAMAGE OR INJURY TO PERSONS OR PROPERTY, COST OF CAPITAL, COST OF SUBSTITUTE OR TEMPORARY EQUIPMENT, DOWNTIME OR CLAIMS OF CUSTOMERS) ARISING OUT OF OR AS A RESULT OF BREACH OF WARRANTY, DEFECT IN MATERIAL OR WORKMANSHIP OR ANY OTHER OBLIGATION OF AVTRON HEREUNDER.

Disclaimer of All Other Warranties

THIS WARRANTY COMPRISES AVTRON'S SOLE AND ENTIRE WARRANTY OBLIGATION TO BUYER, ITS CUSTOMERS AND ASSIGNS IN CONNECTION WITH EQUIPMENT SOLD, ASSIGNED, LEASED OR OTHERWISE DEALT WITH BY AVTRON. ALL OTHER WARRANTIES, EXPRESS OR IMPLIED, INCLUDING, BUT NOT LIMITED TO, WARRANTIES OF MERCHANTABILITY AND FITNESS, ARE EXPRESSLY EXCLUDED.



7900 E. PLEASANT VALLEY RD., INDEPENDENCE, OH 44131, (216) 642-1230, FAX (216) 642-6037